



EAST ASIA ENVIRO SDN BHD (909959-K)

PMT 1159, LORONG PERINDUSTRIAN BUKIT MINYAK 22,
PENANG SCIENCE PARK, TAMAN PERINDUSTRIAN BUKIT MINYAK,
14100 SIMPANG AMPAT, PENANG, MALAYSIA.
Tel: (604)-505 7883, 505 7885, 505 7886 Fax: (604)-505 9883
(GST Reg No: 000291356672)

Technical Data Sheet for Akashi Fron[®] 410A

Technical specifications

Test Item	Specification (AHRI STANDARD 700 - 2019)	Analytical Result
Composition	R32: 50 % (-1.5 % : +0.5 %) R125: 50 % (-0.5 % : +1.5 %)	Pass
Water Content	10 ppm max.	≤ 10 ppm
Acidity (as HCL)	1 ppm max.	≤ 1 ppm
Air and Other Non-Condensable Gas (% by volume @ 25°C)	1.5 % max.	≤ 1.5 %
High Boiling Residue	0.01 % max.	≤ 0.01 %
Halogenated Unsaturates	40 ppm max.	≤ 40 ppm
Chloride	Pass *	Pass
Particulates / Solids	Visually clean to pass	Pass

* Recognized chloride level for Pass / Fail is about 3 ppm.

Packing specifications

1. ISO Tank (16 & 18 MT)
2. 750kg Ton Tank
3. 80kg cylinder
4. 45kg cylinder
5. 10kg disposable can
6. 750g aerosol can