



EAST ASIA ENVIRO SDN BHD (909959-K)

PMT 1159, LORONG PERINDUSTRIAN BUKIT MINYAK 22,
PENANG SCIENCE PARK, TAMAN PERINDUSTRIAN BUKIT MINYAK,
14100 SIMPANG AMPAT, PENANG, MALAYSIA.
Tel: (604)-505 7883, 505 7885, 505 7886 Fax: (604)-505 9883
(GST Reg No: 000291356672)

Technical Data Sheet for Akashi Fron[®] 134a

Technical specifications

Test Item	Specification (AHRI STANDARD 700 - 2019)	Analytical Result
Appearance	Colourless and Clear	Pass
Odour	Odourless	Pass
Purity	99.95 % min.	> 99.95 %
Water Content	10 ppm max.	< 10 ppm
Acidity (as HCL)	1 ppm max.	< 1 ppm
Non-Condensable Gas (23.9°C)	1.5 % max.	< 1.5 %
High Boiling Residue	0.01 % max.	< 0.01 %
Chloride	Pass *	Pass
Particulates / Solids	Visually clean to pass	Pass

* Recognized chloride level for Pass / Fail is about 3 ppm.

Packing specifications

1. ISO Tank (14 – 20 MT)
2. 800kg, 850kg & 950kg Ton Tank
3. 60kg cylinder
4. 13.6kg disposable can
5. 1kg aerosol can