



EAST ASIA ENVIRO SDN BHD (909959-K)

PMT 1159, LORONG PERINDUSTRIAN BUKIT MINYAK 22,
PENANG SCIENCE PARK, TAMAN PERINDUSTRIAN BUKIT MINYAK,
14100 SIMPANG AMPAT, PENANG, MALAYSIA.

Tel: (60)-4-505 7883, 5057885, 5057886 Fax: (60)-4-505 9883

(GST Reg No: 000291356672)

Technical Data Sheet for Akashi Fron® 407F

Test Item	Specification (AHRI 700-2019)	Analytical Result
Composition	R32: 30% (-2 % : +2 %) R125: 30% (-2 % : +2 %) R134a: 40% (-2 % : +2 %)	Pass
Water Content	10 ppm max.	≤ 10 ppm
Acidity (as HCL)	1 ppm max.	≤ 1 ppm
Air and Other Non-Condensable Gas (% by volume @ 25°C)	1.5 % max.	≤ 1.5 %
High Boiling Residue	0.01 % max.	≤ 0.01 %
Halogenated Unsaturates	40 ppm max.	≤ 40 ppm
Chloride	Pass (*)	Pass
Particulates / Solids	Visually clean to pass	Pass

* Recognized chloride level for Pass / Fail is about 3 ppm.